



Statement of Training for Underground Storage Tank Facility Operators

Facility ID# 0111761 Site ID# 199302018
Facility Name Golden Opportunities / Brent & Barbara Properties LLC
Facility Location 148 Main Street PO Box 0444
Facility Town/City Wilton NH 03086-0444

Class A OperatorName Brent Godlewski HO *sl*Training Date July 16, 2014Expiration Date July 16, 2016Class A operator Signature [Signature] Date 07/23/14**Class B Operator**Name Brent Godlewski HO *sl*Training Date July 16, 2014Expiration Date July 16, 2016Class B operator Signature [Signature] Date 07/23/14**Owner**Name Brent Godlewski

Owner Address

148 Main Street

Owner City and State

Wilton NH 03086Owner Signature [Signature] Date 07/23/14Name of Approved Training Program DES

By signing this document you certify under penalty of law that you are familiar with the information submitted, and you believe that the submitted information is true, accurate and complete.

1. Keep a completed copy of this form for owner/operator records.
2. The owner/operator must submit a copy of this to NHDES.

STATE OF NEW HAMPSHIRE
DEPARTMENT OF ENVIRONMENTAL SERVICES
OIL REMEDIATION AND COMPLIANCE BUREAU
PO BOX 95
CONCORD NH 03302-0095
Phone # (603) 271-3899 Fax # (603) 271-2181

List of Class C Operators:

Facility ID

0111761

Facility Name

Golden Opportunities

Facility Location

148 Main Street

Facility Town

Wilton NH

Owner

Brent & Brandee Properties LLC

"I hereby confirm that the below mentioned employee is familiar with the facility layout, understands their responsibility to respond to emergencies and alarms, and agrees to biennial refresher training."

Class C Operator	Date of Training	Expiration Date	Trainer / Training Program
Brent Godlewski	07/16/14	07/16/16	DES

Class A and/or B operator info:

Oil Remediation &
Compliance Bureau


JUL 23 2014

RECEIVED
NHDES



September 2013

Underground Storage Tank Certificate

DES Site #: 195302018 UST Facility ID: 0111761Facility Name: Brant & Brant Paper Co LLCFacility Location: 140 Main StManufacturers' Name: Total ContainmentDate Manufactured: Tank 12/01/1992 Installation Date: 12/01/1992Standard(s) of Design: 112 10/01/1998 10/01/1998Installation Contractor: Eagle Petroleum

Compatible Petroleum and Additives by Percent of Volume: _____

Tank #	16A	26B	37	48	5
Product	Diesel	Heavy Oil	Gasoline	Gasoline	
Dimensions	72"	72"	36" x 21' x 10"	5'4" x 18'	
Capacity	3000	2000	8000	3000	
Serial #					

This certificate must be posted (permanently affixed) under cover, in a visible location (possibly next to the Permit to Operate and / or leak monitor console.

State of New Hampshire -- Administrative Rule Env-Or 405.01(g)

For more information or in case of emergency contact DES at (603) 271-3899

Operator Response Guidelines ^{Actual} (example)

Spill Reporting Procedures

If a spill occurs and any one of the following is true:

- a. 25 gallons or greater
- b. Is not contained
- c. Is not removed within 24 hours
- d. There is impact to groundwater or surface water
- e. Vapors have been emitted that cause an immediate threat to human health

1. Contact your local 911 responder or fire department
2. Call the DES Spill Response and Complaint Investigation Section
 - a. Monday – Friday, 8am to 4pm, (603) 271-3899
 - b. Weekends and Evenings, Call the State Police (603) 223-4381

If a spill occurs where all 5 of the circumstances above are false, contact your A or B operator immediately. If possible, try to mitigate the spill by throwing speedy dry onto the spill area and/or using absorbent pads.

Contact Phones Numbers

1. New Hampshire Department of Safety (24 hours) – 1-800-346-4009 or (603) 223-4381
2. New Hampshire Department of Environmental Services (Monday through Friday, 8 AM – 4 PM) – (603) 271-3899
3. Class A Operator, John Doe, (xxx) xxx-xxxx Brent Godlewski (603) 233-9111
4. Class B Operator, Jane Doe, (xxx) xxx-xxxx Brent Godlewski (603) 233-9111

Malfunctioning Equipment Lock-Out/Tag-Out and Notification Procedures

Nozzle malfunctioning

- a. Bag the nozzle with a "do not use" type bag
- b. Put up signage stating dispenser is not available to use
- c. Notify A or B operator so that they can address the problem
- d. Do not put back in to service till problem has been addressed and fixed

Enunciation Panel is in Alarm

- a. Contact your A or B operator immediately

Initial Mitigation Protocol for Emergencies

Fuel has spilled and is on fire

- a. Immediately hit the emergency pump shutoff switch and call 911.
- b. Activate any other emergency controls