



The State of New Hampshire
DEPARTMENT OF ENVIRONMENTAL SERVICES

Thomas S. Burack, Commissioner



January 28, 2016

**LETTER OF COMPLIANCE for
LETTER OF DEFICIENCY
WMD LOD #15-109**

Charles Thibedeau
CP Management, Inc.
11 Court Street, Suite 100
Exeter, NH 03833

Subject Site: **FITZWILLIAM – 179 NH Route 12 North, LLC; 179 NH Rte12 North
DES Site #198905021, UST Facility #0112678**

Reference: **Letter of Compliance for Letter of Deficiency WMD LOD #15-109**

Dear Mr. Thibedeau:

On December 15, 2015, the New Hampshire Department of Environmental Services ("DES") issued a Letter of Deficiency ("LOD") WMD LOD #15-109 for failure to add locks to all fill caps of temporarily closed tanks, and failure to remove all liquid from temporarily closed tanks to less than one inch at the subject site. On December 31, 2015 and January 26, 2016, DES received documentation to address the correction of the deficiencies cited in the LOD.

DES has reviewed the documentation submitted and based on the information submitted; DES has determined that compliance with WMD LOD #15-109 has been achieved. Therefore, DES issues this Letter of Compliance to Charles Thibedeau of CP Management, Inc.

DES appreciates your cooperation in resolving this matter. If you have any questions regarding this letter please contact the undersigned or Matthew Jones in the Waste Management Division of DES. Matthew can be reached at (603) 271-3899 or by email at Matthew.Jones@des.nh.gov.

Sincerely,

Michael W. Juranty, P.E., Supervisor
Oil Compliance Section
Tel No. (603) 271-6058
Fax No. (603) 271-2181
e-mail: Michael.Juranty@des.nh.gov

cc: 179 NH RT 12 N LLC; PO Box 350; Norwalk, CT 06852
Fitzwilliam Board of Selectmen, PO Box 725, Fitzwilliam, NH 03447DES Legal Unit

ec: Sean Condrón (kcondron@sharpperform.com)
Fitzwilliam Health Officer
Sarah Yuhas-Kirn, Administrator, ORCB
Matt Jones, Compliance & Enforcement Subsection Chief, ORCB
Laura Weit-Marcum, Enforcement Coordinator, ORCB