

Line Test Data Sheet



51 Silkwood Ave. D-2
Belmont, NH 03220
Phone: (603) 527-8202
Fax: (603) 737-0288
Email: jim@atsnh.net

Test Date

12-Sep-19

Site Name

Stafford Oil
227 Court St.
Laconia, NH 03246

Facility#

0111695

Total Lines Tested

Two

Test Pressure

50 psi

Product: Diesel - Tank 9A			System Type: STP				Product: Off Rd. Dsl Tank 9B			System Type: STP		
Time	Data (ml)	Change	GPL	RES	GPH		Time	Data	Change	GPL	RES	GPH
17:00	50.0	-	.0037	-	0.00		17:00	50.0	-	.0037	-	0.00
17:15	49.0	1.0	.0037	0.004	0.01		17:15	49.0	1.0	.0037	0.004	0.01
17:30	50.0	0.0	.0037	0.000	0.00		17:30	50.0	0.0	.0037	0.000	0.00
PASS							PASS					

Both lines tested tight per all applicable State and Federal regulations.

Note: Passing criteria is achieved once THREE consecutive readings are obtained (this can include the initial reading) that are WITHIN .020 GPH of one another and NO MORE THAN the 0.050 GPH leak threshold.

Tester's Signature:

Jim Spiller