

# Spill Containment Hydrostatic Testing



51 Silkwood Ave. D-2  
Belmont, NH 03220  
Phone: (603) 527-8202  
Fax: (603) 737-0288  
Email: sales@atsnh.net

## Test Date

3-Jul-19

## Site Name & Address

Stafford Oil  
227 Court St.  
Laconia, NH 03247

## Facility# / Site#

0115695 / 199602042

## Test Data

| Tank#      | 7                 |          | Product           |        | Gas         | Tank#      | 8                 |          | Product           |        | Gas         |
|------------|-------------------|----------|-------------------|--------|-------------|------------|-------------------|----------|-------------------|--------|-------------|
| Make       | Fairfield         |          | Model             | SCM-5  |             | Make       | Fairfield         |          | Model             | SCM-5  |             |
| Start Time | Reading in Inches | End Time | Reading in Inches | Change | Pass / Fail | Start Time | Reading in Inches | End Time | Reading in Inches | Change | Pass / Fail |
| 5:10 PM    | 11.25             | 6:10 PM  | 11.25             | 0.00   | PASS        | 5:10 PM    | 11.25             | 6:10 PM  | 11.25             | 0.00   | PASS        |

  

| Tank#      | 9A                |          | Product           |        | Diesel      | Tank#      | 9B                |          | Product           |        | Off Rd      |
|------------|-------------------|----------|-------------------|--------|-------------|------------|-------------------|----------|-------------------|--------|-------------|
| Make       | Farfield          |          | Model             | SCM-5  |             | Make       | Fairfield         |          | Model             | SCM-5  |             |
| Start Time | Reading in Inches | End Time | Reading in Inches | Change | Pass / Fail | Start Time | Reading in Inches | End Time | Reading in Inches | Change | Pass / Fail |
| 5:15 PM    | 11.00             | 6:15 PM  | 11.00             | 0.00   | PASS        | 5:15 PM    | 11.50             | 6:15 PM  | 11.50             | 0.00   | PASS        |

*James M. Spiller*