



## Stage I - System Testing

☐ Unwitnessed    ☐ Partially Witnessed    ☒ Witnessed    State Inspector: Steve Scotten  
☐ Complete Test    ☐ Retest (Complete)    ☐ Retest (Partial)    State ID: 0111376

Facility Information	Testing Firm Information
Name: <u>Epsom circle market</u>	Company Name: <u>Gaftek Inc.</u>
Address: <u>1921 Dover Rd.</u>	Tester Name: <u>Mike Cormier</u>
City/State: <u>Epsom New Hampshire</u>	City/State: <u>Epsom, NH</u>
Zip: <u>03234</u> Tel.: <u>603-528-1991</u>	Zip: <u>03234</u> Tel.: <u>(603) 736-5898</u>

Stage I Equipment					
Type:	<input type="checkbox"/> Coax	<input type="checkbox"/> Two Point	<input checked="" type="checkbox"/> Manifold	Number of P/V caps: <u>1</u>	
P/V Cap Test:	1	2	3	4	5
P	Pass				
V	Pass				
				<input type="checkbox"/> 2" Vapor Recovery Piping <input checked="" type="checkbox"/> 3" Vapor Recovery Piping	

Test Results and Comments				
Tank #:	1	2	3	4
1 Product Grade	RNL	SNL		
2 Actual Tank Capacity (Gallons)	10070	6074		
3 Gallons Present	453	1384		
4 Ullage (Gallons)	9617	4690		
5 Nitrogen Flow Rate	5	5		
6 Initial Pressure (inches H <sub>2</sub> O)	10	10		
7 Start Time	1115			
8 Pressure after 1 minute	9.99			
9 Pressure after 2 minutes	9.99			
10 Pressure after 3 minutes	10.01			
11 Pressure after 4 minutes	10.04			
12 Final Pressure after 5 minutes	10.07			
13 Allowable Final Pressure	9.68	N/A	N/A	
<input checked="" type="checkbox"/> Passed Test <input type="checkbox"/> Failed Test - Reason(s): _____				

Technician Name: Mike Cormier    Date: 11/22/19



160 Perry Road  
Bangor, ME 04401

84D Warren Avenue  
Westbrook, ME 04092

2083 Dover Road  
Epsom, NH 03234

155 Memorial Drive  
Shrewsbury, MA 01545

888-485-5731 (Tel.)

207-217-6520 (Fax)



## Form 1

## Pressure/Vacuum (P/V) Vent Valve Data Sheet

Facility Name:	Epsom circle market	Test Date:	11/22/19
Address:	1921 Dover Rd.	Test Company:	Gaftek, Inc.
City :	Epsom New Hampshire	Tester Name:	Mike Cormier

<b>P/V Valve Manufacturer:</b>	Opw	<b>Model Number:</b>	723v	<b>Pass</b>	<b>Fail</b>
<b>Manufacturers Specified Positive Leak Rate (CFH):</b>	.05	<b>Manufacturers Specified Negative Leak Rate (CFH):</b>	.21	✓	
Measured Positive Leak Rate (CFH):	.02	Measured Negative Leak Rate (CFH):	.07		
Positive Cracking Pressure (in. H <sub>2</sub> O):	3.70	Negative Cracking Pressure (in. H <sub>2</sub> O):	6.54		

<b>P/V Valve Manufacturer:</b>	N/A	<b>Model Number:</b>		<b>Pass</b>	<b>Fail</b>
<b>Manufacturers Specified Positive Leak Rate (CFH):</b>		<b>Manufacturers Specified Negative Leak Rate (CFH):</b>			
Measured Positive Leak Rate (CFH):		Measured Negative Leak Rate (CFH):			
Positive Cracking Pressure (in. H <sub>2</sub> O):		Negative Cracking Pressure (in. H <sub>2</sub> O):			

<b>P/V Valve Manufacturer:</b>	N/A	<b>Model Number:</b>		<b>Pass</b>	<b>Fail</b>
<b>Manufacturers Specified Positive Leak Rate (CFH):</b>		<b>Manufacturers Specified Negative Leak Rate (CFH):</b>			
Measured Positive Leak Rate (CFH):		Measured Negative Leak Rate (CFH):			
Positive Cracking Pressure (in. H <sub>2</sub> O):		Negative Cracking Pressure (in. H <sub>2</sub> O):			

<b>P/V Valve Manufacturer:</b>	N/A	<b>Model Number:</b>		<b>Pass</b>	<b>Fail</b>
<b>Manufacturers Specified Positive Leak Rate (CFH):</b>		<b>Manufacturers Specified Negative Leak Rate (CFH):</b>			
Measured Positive Leak Rate (CFH):		Measured Negative Leak Rate (CFH):			
Positive Cracking Pressure (in. H <sub>2</sub> O):		Negative Cracking Pressure (in. H <sub>2</sub> O):			