



The State of New Hampshire
Department of Environmental Services



Robert R. Scott, Commissioner

REGULAR MAIL

January 14, 2021

W. LLOYD HELM
FALCON PETROLEUM, LLC
PO BOX 522
MILLERTON, NY 12546

Subject: **Canterbury**, Singh Mart, 125 West Rd
NHDES Site #199306030, UST Facility ID #0110079

Reference: **Construction Approval Extension Request** prepared by Lauren Simons, GRJH, Inc., dated January 5, 2021, pursuant to the requirements of Env-Or 407.04(h)

Dear Mr. Helm:

The New Hampshire Department of Environmental Services, Waste Management Division (NHDES) has received Lauren Simons' January 5, 2021, request for a construction approval extension pursuant to the requirements of the New Hampshire Code of Administrative Rules Env-Or 400, Underground Storage Tank Facilities ("the UST Rules"). Specifically, it is requested that NHDES extend the January 16, 2020, conditional construction approval for the UST system installation at the subject facility. After reviewing the matter in accordance with the UST Rules, NHDES approves your request for extension.

The construction approval issued January 16, 2020, is hereby extended for one additional year, to expire on January 16, 2022. Please note that in order for operational approval of the facility to be granted, all requirements and conditions of the construction approval originally granted on January 16, 2020, shall be met. No substantial design changes to any part of the system shall be made without prior approval from NHDES in accordance with the requirements of Env-Or 407.04(e).

Please contact me should you have any questions regarding this extension of the conditional construction approval.

Sincerely,

Chad M. Hayes, P.E.
Oil Remediation and Compliance Bureau
Tel: (603) 271-0686
Email: Chad.Hayes@des.nh.gov

Enclosures: Construction Approval dated January 16, 2020
UST Registration Form
UST/AST Closure Notification Form
Stage I & II Vapor Recovery Notification Form

cc: Canterbury Fire Chief
Lauren Simons, GRJH, Inc.
Mark Antonia P.E., Antonia Design LLC
Steve Scotton, NHDES
Matt Jones, NHDES

www.des.nh.gov



The State of New Hampshire
Department of Environmental Services



Robert R. Scott, Commissioner

REGULAR MAIL

January 16, 2020

W. LLOYD HELM
FALCON PETROLEUM, LLC
PO BOX 522
MILLERTON, NY 12546

Subject: Canterbury, Singh Mart, 125 West Rd
NHDES Site #199306030, UST Facility ID #0110079

UST System Construction Plan prepared by, Antonia Design, LLC
dated November 15, 2019 and last revised January 9, 2020

Dear W. LLOYD HELM:

The New Hampshire Department of Environmental Services, Waste Management Division (NHDES) has completed its review of the subject plans forwarded to us by your engineer for the proposed 4,000-gallon diesel underground storage tank #4 (UST) system installation. NHDES conditionally approves the application dated November 18, 2019, plan sheet 1 of 2 last revised January 9, 2020, and plan sheet 2 of 2 last revised January 7, 2020, for construction in accordance with the requirements of Env-Or 407.04 of the New Hampshire Code of Administrative Rules, Env-Or 400, Underground Storage Tank Facilities (UST Rules). **The approval is subject to the conditions listed below:**

- A. **THE FACILITY OWNER IS RESPONSIBLE** FOR PROPER INSTALLATION OF THE NEW OR SUBSTANTIALLY MODIFIED UST SYSTEM. ENSURE THAT THE CERTIFIED TANK INSTALLER RECEIVES A COPY OF THIS DOCUMENT **AND A COPY OF THE NHDES APPROVED PLANS AS NOTED ABOVE REFERENCED BY PAGE NUMBERS AND DATES.**
- B. **Closure and site assessment requirements shall be performed in accordance with Env-Or 408.04 through Env-Or 408.10 for tanks, sump replacements, piping replacements (including placed in existing ducts) and piping removals.** Any indication of contamination requires immediate notification to NHDES pursuant to the requirements of Env-Or 604.06. This construction approval in no way alleviates the owner's responsibility to perform adequate contamination cleanup acceptable to NHDES, prior to installation of the new system. **A notification form shall be submitted to NHDES 14 days prior to closure of the existing system and a closure report shall be submitted to NHDES within 30 days of the site assessment required for both tank and piping closures.** Closure shall be supervised by an ICC certified tank remover (certification in category U2).
- C. The approval is valid for one year from the date of issuance, per Env-Or 407.04(f). If construction pursuant to the approval has not commenced within one year, the approval shall be void, per Env-Or 407.04(g). If construction has commenced but is not completed within one year, the owner shall notify NHDES and may request a one-year extension if meeting the conditions of Env-Or 407.04(h)(1) and (h)(2).

www.des.nh.gov

PO Box 95, 29 Hazen Drive, Concord, NH 03302-0095

Telephone: (603) 271-3899 Fax: (603) 271-2181 TDD Access: Relay NH 1-800-735-2964

- D. An owner shall not cause or allow any construction or other activity that is not in accordance with the approved plans and all terms and conditions of NHDES's approval, per Env-Or 407.04(e). The construction of the system shall strictly comply with the approved plans and specifications. No construction changes will be allowed without prior approval from a New Hampshire licensed professional engineer (NH P.E.) and NHDES.
- E. Any person installing a UST or UST system component shall be certified by the International Code Council in the UST system/retrofitting (certification in category U1) and have an understanding of federal UST regulations and industry codes and practice, per Env-Or 407.05(a) and (b)(2). Additionally, **the certified installer shall be a qualified installer by the manufacturer of the equipment being installed for every component of the system, per Env-Or 407.05(b)(1).** Installation shall comply with applicable standards and fire codes, per Env-Or 407.05(c) and (d).
- F. The certified tank installer shall perform applicable tightness testing after installation and prior to backfill to determine tightness of the primary piping, secondary containment piping, vent piping, and all spill containment equipment in accordance with Env-Or 406.05 through Env-Or 406.08, per Env-Or 407.08(a) and (b). The certified tank installer shall certify the results of all tightness performed and provide the certified results to NHDES and the owner at the time of backfill inspection of the system, per Env-Or 407.08(c).
- G. The certified tank installer shall test all installed sumps for tightness in accordance with Env-Or 406.15. The certified tank installer shall certify and provide the certified test results to NHDES and owner at the time of the backfill inspection of system, per Env-Or 407.08(c).
- H. The owner shall notify NHDES of the completion of installation for a new or substantially modified system at least 5 NHDES business days prior to backfilling the tank top and/or piping, to arrange for an inspection, in accordance with 407.07(b). The new system shall not be backfilled or placed into service until NHDES has performed an inspection, per Env-Or 407.07(e) and (f).
- I. In addition to the certified tightness testing results required at the backfill inspection per Env-Or 407.08(c), **per Env-Or 407.08(e)(2), following the completion of a new or substantially modified existing system and prior to dispensing or consumption the certified tank installer shall submit to NHDES, via OneStop, certified test results for all tests indicated in Env-Or 407.08(e)(1):**
- a. All line leak detectors passed a functionality test;
 - b. All overfill devices passed a functionality test;
 - c. All spill containment passed integrity testing;
 - d. All containment sumps passed integrity testing;
 - e. All leak monitoring system components pass a functionality test; and
 - f. All motor fuel dispensing tank systems passed primary containment testing.
- J. At least 8 NHDES working hours prior to an inspection by NHDES, the owner shall submit to NHDES a letter prepared and stamped by a New Hampshire licensed professional engineer (NH P.E.), stating that the installed UST system has been inspected by a NH P.E. to verify that the system was constructed in accordance with NHDES's approved plans and specifications, per Env-Or 407.07(c). If the NH P.E.'s inspection reveals any discrepancies between the system as installed and the approved plans and specifications, the owner shall

submit to NHDES as-built record drawings prepared and stamped by a NH P.E., per Env-Or 407.07(d).

- K. All line leak detectors shall be tested in accordance with the manufacturer's requirements. The certified tank installer shall certify that all line leak detectors passed a functionality test and submit the certified test results to NHDES before any regulated substance is dispensed or used for consumption, as applicable, per Env-Or 407.08(d).
- L. **Prior to authorization to dispense to the public** all **Primary Containment Systems** shall be **successfully** tested as defined in Env-Or 406.17. Testing shall be for tightness per Env-Or 406.17(b), which includes **any motor fuel dispensing UST system** dispensing gasoline, diesel, kerosene, Jet and Avgas. The certified tank installer shall provide the certified test results to NHDES per Env-Or 406.17(e).

Specific requirements for the tank(s) storing gasoline: As this facility is in one of the counties of Hillsborough, Merrimack, Rockingham or Strafford the pressure decay **and** pressure/vacuum (PV) vent cap testing for the gasoline tank(s) shall be **witnessed** by a NHDES inspector. This applies to all new facilities and former stage II facilities no later than 15 days following completion of the work in accordance with the requirements of Env-Or 505.03(c).

Procedure to complete:

1. The facility owner (or representative) shall submit the *Stage I & II Vapor Recovery Notification Form (attached)* to NHDES at least 7 working days prior to the planned date of test for coordination and scheduling of a date/time with NHDES staff per Env-Or 505.11.
 2. The Primary Containment System(s) testing shall be completed following a successful NHDES final site installation approval.
 3. **Options:**
 - a. Per item #1 above, coordinate with NHDES to arrange a **witnessed** successful pressure decay and pressure/vacuum (PV) vent cap test per the requirements of Env-Or 406.17 as described above prior to dispensing to the public; or
 - b. Prior to dispensing to the public provide **unwitnessed** successful pressure decay and pressure/vacuum (PV) vent cap test results per the requirements of Env-Or 406.17 to allow dispensing to begin to the public. But no later than 15 days following completion of the work in accordance with the requirements of Env-Or 505.03(c) a NHDES **witnessed** test must be completed (provide coordination with Item #1 above). **Note:** this option would require the test to be completed twice, but doesn't delay the opening of the facility.
- M. Prior to NHDES authorizing an underground storage tank system to be placed into service, the owner shall submit to NHDES final certification by a New Hampshire licensed professional engineer or the certified tank installer that the installation has been completed and is in accordance with **NHDES's approved plans, as-built record drawings** and all terms and conditions, per Env-Or 404.04(i).

- N. A new or amended registration form, respectively, for new systems or substantial modifications of existing systems, shall be filed with NHDES at the time of the final inspection of the system, per Env-Or 404.01(f). **Use form dated September 2013.**
- O. Per RSA 146-C:17, effective August 8, 2012, no person shall operate an underground storage facility without designated class A, B, and C operators who have been trained and certified in accordance with an approved training program. Information can be obtained by contacting the Oil Compliance and Enforcement section's UST Operator Training Specialist, Spruce by dialing (603) 271-0673 or by email at Spruce.Wheelock@des.nh.gov. Additional information, including approved operator training programs, upcoming class dates, Operator Training forms, and more, by visiting the Operator Training website at: <http://des.nh.gov/organization/divisions/waste/orcb/ocs/ustp/operator-training/index.htm>
- P. The State of New Hampshire and NHDES shall incur no liability by reason of this plan review for this proposed facility. The comments in this letter are based on plans and specifications supplied by the site owner or responsible party. **This plan review does not guarantee the adequacy of the approved plan nor does it supersede any federal, state, or local ordinances or regulations.**
- Q. This approval in no way constitutes an endorsement or approval of any material, design, or workmanship, but only that the plans and specifications, as submitted, appear to fulfill the requirements of the UST Rules. Nor does the approval relieve the owner of the responsibility to install the system according to acceptable engineering design and construction practices.
- R. **State law does not preempt local authority.** The owner must notify the appropriate local officials and comply with any local ordinances and permitting requirements. This includes building permits, notification to the fire department, and any approvals and inspections.
- S. If the ICC installer is not already identified on the application. **Prior to starting any UST construction at the site the owner shall provide written notice to the NHDES plan approval engineer noted below on the projects ICC certified installer.** This written notice shall include all Information as required per [Env-Or 407.02(m)].
- T. **Temporary Closure:** Existing tanks #2 and #3 have been in temporary closure since February 2017. Prior to authorizing the new UST system to be placed into service the necessary requirements to place these tanks back into services. Please contact Matthew Jones at (603) 271-2986 or Matthew.Jones@des.nh.gov for a complete list of requirements.
- U. **Inspection Report Dated November 19, 2019:** Existing tanks #1, #2 and #3 have outstanding compliance issues relative to an inspection completed on November 19, 2019. Prior to authorizing the new UST system to be placed into service the necessary documentation to demonstrate compliance with the inspection items shall be submitted to DES. Please contact Steve Scotton at (603) 271-2933 or Stephen.Scotton@des.nh.gov.


A permit to temporarily discharge groundwater, pursuant to Env-Wq 402 may be required prior to dewatering necessary for the installation of an UST system. Applications and permitting information can be obtained by calling (603) 271-2858 or (603) 271-2513.

Falcon Petroleum, LLC
NHDES Site #199306030, UST Facility ID #0110079
January 16, 2020
Page 5 of 5

The owner shall also be responsible for any damages and regulatory fines due to spilled or leaked petroleum caused by non-compliance, faulty design, or poor workmanship. The State of New Hampshire shall not incur any liability as a result of any spill, leak, failure, or damage of any kind related to the UST facility.

Please contact me should you have any questions regarding this conditional construction approval.

Sincerely,

A handwritten signature in black ink that reads "Chad M. Hayes". The signature is written in a cursive, slightly slanted style.

Chad M. Hayes, P.E.
Oil Remediation and Compliance Bureau
Tel: (603) 271-0686
Fax: (603) 271-2181
Email: Chad.Hayes@des.nh.gov

Enclosures: Closure Notification Form
 UST Registration Form
 Stage I & II Vapor Recovery Notification Form

ec: Canterbury Fire Chief
 Mark Antonia P.E., Antonia Design LLC
 Steve Scotton, NHDES
 Matt Jones, NHDES