



PORTLAND PUMP COMPANY
Petroleum Facility Services

11 Border Rd.
Scarborough, ME 04074

Pressure Decay & Stage II Vapor Test Report

FACILITY INFORMATION		FACILITY PARAMETERS			
Name: <i>Newmarket Mini Mart</i>	Representative Name: <i>Chris Patel</i>	PHASE II SYSTEM TYPE (Check One) Balance <input type="checkbox"/> Hirt <input type="checkbox"/> Red Jacket <input type="checkbox"/> Hasstech <input type="checkbox"/> Healy <input type="checkbox"/> Other _____ Manifolded? <input type="checkbox"/> Y <input checked="" type="checkbox"/> N			
Address: <i>44 Exeter St</i>	Representative Title: <i>owner</i>				
City: <i>Newmarket</i>	Phone No: _____				
State: <i>NH</i>	Zip Code: <i>05857</i>				
Source: GDF Vapor Recovery System					
Permit Conditions:					
REG #: _____					
A/C #: _____					
Number of Nozzles Served by Tank #1: <i>8</i>					
Number of Nozzles Served by Tank #2: _____					
Number of Nozzles Served by Tank #3: _____					
Number of Nozzles Served by Tank #4: _____					
Applicable Regulations: None		VN Recommended: None			
Test Results and Comments					
	Tank #:	1	2	3	4
Product Grade		Regular	Super	Diesel	Kerosene
Actual Tank Capacity, gallons		<i>12,000</i>			
Gasoline Volume		<i>5,744</i>			
Ullage, gallons		<i>6,256</i>			
Initial Pressure, inches H ₂ O		<i>10"</i>			
Pressure After 1 Minute, inches H ₂ O		<i>9.99</i>			
Pressure After 2 Minutes, inches H ₂ O		<i>9.99</i>			
Pressure After 3 Minutes, inches H ₂ O		<i>9.98</i>			
Pressure After 4 Minutes, inches H ₂ O		<i>9.98</i>			
Final Pressure After 5 Minutes, inches H ₂ O		<i>9.98</i>			
Allowable Final Pressure		<i>9.28</i>			
Test Conducted by: <i>John Bickupiak</i>	CTI #: <i>1811</i>	Test Company: Portland Pump Company		Date of Test: <i>6-18-21</i>	