

Annual Leak Monitoring and Overfill Protection Test Form For Underground or Aboveground Storage Tank Systems

N. H. Code of Administrative Rules Env-Or 406.18 and Env-Or 406.20 (for UST Facilities) and
N. H. Code of Administrative Rules Env-Or 306.12, (for AST Facilities)

The New Hampshire Department of Environmental Services (NHDES) has developed this form to document the required annual testing of leak monitoring and/or overfill protection equipment at this UST or AST storage facility.

Facility Name: Newmarket Mini Mart UST ☒ AST ☐ DES Site No. / Facility No. 0114927 / 199004005

Facility Address: 44 Exeter St City: Newmarket Zip: 03857

A. Annual Leak Monitoring and/or Overfill Protection Test Results

Complete the following checklist using: Y = Yes, N = No, N/A = Not Applicable

1. Leak monitor and/or overfill protection equipment. List all tested with manufacturer's name and model#: Vender Root TLS750

		Tank #:			
2.	Leak monitor console assignments are correctly programmed and labeled for all sensors.	7	<input checked="" type="checkbox"/>		
3.	<u>Tank</u> secondary containment sensor is positioned per manufacturer's requirements.	7	<input checked="" type="checkbox"/>		
4.	<u>Piping</u> secondary containment (piping, intermediate, and or dispenser sump) sensors are positioned per manufacturer requirements to monitor all containment.	7	<input checked="" type="checkbox"/>		
5.	Brine level of the tank interstitial space is within the manufacturers operating range.	NA			
6.	All secondary containment is liquid tight and free of debris, water and regulated substance.	Y			
7.	All sensors were visually inspected, manually tested, confirmed operational and reset.	Y			
8.	The leak monitor console <u>audible</u> alarm is confirmed operational and reset.	Y			
9.	The leak monitor console <u>visuals</u> alarms are operational and reset.	Y			
10.	The communication equipment (e.g. modem) is operational for leak monitoring systems and will relay alarms to a remote station.	NA			
11.	Overfill alarm sensors and shutoff devices, as applicable, were manually activated and verified to be at the proper operational setting. (Required Triennially for USTs, Annually for ASTs)	NA			
12.	In summary, the leak monitor and/or overfill protection systems are confirmed to be in proper operation per manufacturer's requirements. All sensors are reset and alarms have been cleared.		<input checked="" type="radio"/> Yes	<input type="radio"/> No	

If your answer is No, then describe on the reverse side of this form how and when these items will be corrected.

B. Certification

I hereby certify that the equipment identified in this document was tested for proper operation in accordance with manufacturer's requirements.

Name (print): Josh Bisleyak Company Name: Portland Pump

Company Address / State / Zip: 11 Border Rd Scarborough ME 04074

Tester's Signature: [Signature] Phone No.: (207) 883-4317 Test Date: 6-21-21

C. Record Keeping and Reporting Instructions

- Keep a completed copy of this form for owner/operator records.
- The owner/operator must submit a copy of the annual test report to NHDES within 30 days of testing to:

NH DEPARTMENT OF ENVIRONMENTAL SERVICES
OIL REMEDIATION AND COMPLIANCE BUREAU
PO BOX 95, CONCORD NH 03302-0095
Phone # (603) 271-3899 Fax # (603) 271-2181