

Triennial Spill Containment Integrity Test Form for Underground Storage Tank Systems Oil Remediation and Compliance Bureau



RSA 146-C, Env-Or 406.07, 406.12

ATTENTION: This form is a document used to facilitate the submission of information required under Env-Or 400. Nothing in this form is required to be submitted to the department unless such a requirement is expressly stated in the rules. If there is any inconsistency between this document and the adopted rules, only those requirements specified in the rules are applicable and enforceable. Use of this form to submit information required under the rules is OPTIONAL.

The owner/operator must submit a copy of the test report to NHDES within 30 days of testing.

| he owner/operator must submit a copy of the test rep | OFT TO NAMES WITHIN 30 days of testing. |
|---|--|
| Facility Information | |
| NHDES Site # 2000 12019 | Facility ID # 0111910 |
| Facility Name: SOMERSWORTH ONE STOP II | |
| Physical Address of Facility: 55 ROUTE 108 | Town/City: SOMERSWORTH |
| Owner Information | |
| Name: SEABROOK ONE STOP INC. | |
| Mailing Address: 720 LAFAYETTE RD. SEABROOK, | NH 03874 |
| Daytime Phone: (603) 474 - 0510 | Email (Optional): |
| Test Date: 08/29/2022 1. Containment model number and manufactu T-5A (PC) T-5 | urer's name (List out all manufacturers and models if different.): |
| 2. Test Method: HYDROSTATIC | |
| TECT DECLUTE. | Tank # 5A 5B |

| YLL (| CONTAINMENT INTEGRITY TEST RESULTS: | Tank # | 5A | 5B | |
|-------|---|---------------------|---------|---------|--|
| 3. | Specify single-walled or double-walled (SW | or DW) | SW | SW | |
| 4. | Specify is fill of vapor recovery conserved | of VR) | F | F | |
| 5. | The primary and secondary containment, if applicable | e, is free or N) | Υ | Y | |
| 6. | Start time of test. | | 1:40 PM | 1:40 PM | |
| 7. | Liquid or pressure level at beginning of test. (hydrostatic: inches to the nearest 1/8 inch) (vacuum: inches water column or hg) | | 15.0" | 13.0" | |
| 8. | End time of test. | | 2:40 PM | 2:40 PM | |
| 9. | Liquid or pressure level at end of test. (hydrostatic: inches to the nearest 1/8 inch) (vacuum: inches water column or hg) | | 15.0" | 13.0" | |
| 10. | In summary, the spill bucket is confirmed to be in operation per manufacturer's requirements. Enter "P" for Pass or "F" for Fail | | P | Р | |

If your answer is No for any of the above, then describe on the reverse side of this form how and when these items will be corrected. Any tightness test failure shall be reported to NHDES within 24 hours of receiving notice of failure. Please be aware that no transfer shall be made to a UST system that is not equipped with spill containment as required by Env-Or 405.05.

NHDES email: orcb.wmd@des.nh.gov Telephone: (603) 271-3899 Fax: (603) 271-2181 TDD Access: Relay NH (800) 735-2964 P.O. BOX 95, Concord, NH 03302-0095

| operation in accordance with Env-Or 400 and manufact | the equipment identified in this document and tested for proper curer's requirements. |
|--|--|
| Festing Company Name: <u>NEXTEST</u> | Testing Company Phone #: 401-723-0247 |
| Testing Company Address: 872 SMITHFIELD AVE. SUIT | TE 202 LINCOLN, RI 02865 |
| Technician Name (Print): BRYAN COURNOYER | Technician Signature: |
| Describe how and when any "No" items will be correct | ted: |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |