

Facility Information
NHDES Site # 200012019

Facility Name: SOMERSWORTH ONE STOP II

Physical Address of Facility: 55 ROUTE 108

Annual Line Leak Detector Test Form for AST and UST Systems



Oil Remediation and Compliance Bureau

AST: RSA 146-A, Env-Or 306.12; UST: RSA 146-C, Env-Or 406.07, 406.09

ATTENTION: This form is a document used to facilitate the submission of information required under Env-Or 400. Nothing in this form is required to be submitted to the Department unless such a requirement is expressly stated in the rules. If there is any inconsistency between this document and the adopted rules, only those requirements specified in the rules are applicable and enforceable. Use of this form to submit information required under the rules is OPTIONAL.

NHDES has developed this form to help you document the required annual testing of the line leak detector (LLD) at this storage tank facility. Please consult with the LLD manufacturer for specific guidelines on testing.

Facility ID # 0111910

Town/City: SOMERSWORTH

THE OWNER SHALL SEND THE LLD TEST REPORT TO THE DEPARTMENT NO LATER THAN 30 DAYS AFTER THE DATE OF THE TEST.

Owner Information										
Name: SEABROOK ONE STOP INC.										
Mailing Address: 720 LAFAYETTE RD. SEABROOK, NH 03874										
Daytime Phone: (603) 474-0510				Email (Optional):						
 As required by rules, all pressurized piping shall be equipped with an automatic line leak detector, which shall restrict or stop the flow of the stored substance upon detecting a leak at a rate of 3 gallons per hour at a pressure of 10 pounds per square inch line pressure. Automatic line leak detectors shall be tested annually to confirm that they are operating according to manufacturer's requirements. Line leak detector is required to be tested in-place. Do not remove and test outside the system. 										
Testing Information and Results:	AST		UST 🛭		Tes	ting Dat	e: <u>09/19</u>	/2023		
Tank # (for split tanks use 1(a), 1(b))	Tank #5A		Tank #		Tank #		Tank #			
Test Location:	Crash Valve									
Product Stored: (gas, diesel, etc.)	Regular									
Capacity: (gallons)	10,000									
LLD Manufacturer:	FE-Petro		100010-0000							
LLD Model Number:	STP-MLD									
Tested Leak Rate: (gallons per hour)	3.0									
Results:	□ Pass	☐ Fail	☐ Pass	Fail	☐ Pass	☐ Fail	☐ Pass	☐ Fail	☐ Pass	☐ Fail
Complete the following only if any of the above	e LLDs have	e failed a	nd repla	ced with N	IEW LLDs.					
REPLACED LLD Manufacturer:										
LLD Model Number:										
Tested Leak Rate: (3 gallons per hour max)			W 1 = 1 = 1							
Results:	Pass	☐ Fail	☐ Pass	s 🗌 Fail	☐ Pass	☐ Fail	☐ Pass	☐ Fail	☐ Pass	☐ Fail
An automatic line leak detector failure shal	l be indicat	ed by a	leak rati	e of great	er than 3	gallons r	er hour a	t a pres	sure of 1	0 pound

NHDES email: orcb.wmd@des.nh.gov
Telephone: (603) 271-3899 Fax: (603) 271-2181 TDD Access: Relay NH (800) 735-2964
PO BOX 95, Concord, NH 03302-0095

per square inch line pressure within one hour. The failed line leak detector shall be repaired or replaced immediately. The affected

<u>Certification</u> – I hereby certify that the equipment identified in this document was tested for proper operation in accordance with manufacturer's requirements.

Testing Company Name: _	NEXTEST	Testing Company Phone	#								
Testing Company Address	: 2220 PLAINFIELD PIKE STE. 202 Cro	uston bi calan									
Technician Name (Print): _	BRYAN COURNOYER	Technician Signature:	By-								
Certification #	Ex	piration Date:									
Description of how and when any "No" items will be corrected:											
Description of now and	when any "No" items will be corre	<u>ctea</u> : 									

www.des.nh.gov