

# LBI LAMOUNTAIN BROS., INC.

37 FEDERAL HILL RD,  
OXFORD, MA 01540  
P: 508-987-5322  
[WWW.LAMOUNTAINBROS.COM](http://WWW.LAMOUNTAINBROS.COM)

January 19, 2024

RE: BP Gas Station, DES ust fac id# 0113095  
4 Amherst St.  
Milford, NH  
Test results

LaMountain Bros., Inc. completed hydrostatic testing of the spill containment manholes at the above referenced site. All equipment spill containment manholes were tested based upon the more stringent of the requirements (NH DES ENV OR-400, manufacturers testing requirements, PEI RP1200) which is determined to be within one inch of the top for a duration of three (3) hours with no drop. The results of our hydro testing are as follows:

Spill containment manhole:	Date	Start	End	Result
Diesel	01-12-24	08:00	12:00	<b>Pass</b>
Regular Fill	01-12-24	08:00	12:00	<b>Pass</b>
Regular Vapor	01-12-24	08:00	12:00	<b>Pass</b>

Please feel free to give me a call should you have any questions regarding this or if you require any additional information.

Sincerely,



Henry LaMountain