



ANALYTICAL RESULTS

Batch ID/Form: B309387 - TOTAL COLIFORM RULE

Submitting Lab ID: 3000

PWS ID/Name: 0081010 - ANDOVER VILLAGE DIST - ANDOVER

Report Date: 12/14/2023

Collector: LISA MEIER

Phone: 603-344-1114

Collect Date: 12/12/2023 08:10:00

Lab Sample ID: B309387001

Matrix: WATER

Received: 12/12/2023 09:21:00

Sample Location ID: 020

Sample Type: ROUTINE-SAMPLE

Compliance Period: DEC 2023

Description: 6 BOATHOUSE LN

Receipt Temp.: 12 C

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
---------	---------	-------	-----	----	---------------	---------------	--------------	---------	-------

Analytical Method: 9223B

Analyzing Lab: 3000-NEW HAMPSHIRE DHHS PUBLIC HEALTH LABORATORIES

ESCHERICHIA COLI	ABSENT	P-A/100ML			12/12/2023 09:48:00	12/13/2023 13:06:00	2525		
TOTAL COLIFORMS	ABSENT	P-A/100ML			12/12/2023 09:48:00	12/13/2023 13:06:00	2500		

Analytical Method: Field Result SM 9223B

TOTAL RESIDUAL CHLORINE	0.36	MG/L							
-------------------------	------	------	--	--	--	--	--	--	--

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.