



**ANALYTICAL RESULTS**

**Batch ID/Form:** B401585 - TOTAL COLIFORM RULE

**Submitting Lab ID:** 3000

**PWS ID/Name:** 0211010 - BENNINGTON WATER DEPT - BENNINGTON

**Report Date:** 04/04/2024

**Collector:** MATT MILLER

**Phone:** 603-588-2433

**Collect Date:** 04/02/2024 09:45:00

**Lab Sample ID:** B401585001

**Matrix:** WATER

**Received:** 04/02/2024 11:12:00

**Sample Location ID:** 001

**Sample Type:** ROUTINE-SAMPLE

**Compliance Period:** APR 2024

**Description:** TOWN HALL SCHOOL ST

**Receipt Temp.:** 13 C

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
<b>Analytical Method:</b> 9223B		<b>Analyzing Lab:</b> 3000-NEW HAMPSHIRE DHHS PUBLIC HEALTH LABORATORIES							
ESCHERICHIA COLI	ABSENT	P-A/100ML			04/02/2024 12:23:00	04/03/2024 08:23:00	2525		
TOTAL COLIFORMS	ABSENT	P-A/100ML			04/02/2024 12:23:00	04/03/2024 08:23:00	2500		
<b>Analytical Method:</b> Field Result									
RESIDUAL FREE CHLORINE	0.01	MG/L							

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.