



ANALYTICAL RESULTS

Batch ID/Form: 2403-00707 - TOTAL COLIFORM RULE

Submitting Lab ID: 1015

PWS ID/Name: 0511030 - NORTH CONWAY WATER PCT - CONWAY

Report Date: 03/08/2024

Collector: MARK EWING

Phone: 603-356-5382

Collect Date: 03/05/2024 09:10:00

Lab Sample ID: 2403-00707-002

Matrix: WATER

Received: 03/05/2024 14:00:00

Sample Location ID: 002

Sample Type: ROUTINE-SAMPLE

Compliance Period: MAR 2024

Description: N CONWAY FIRE STN

Receipt Temp.: 13 C

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
Analytical Method: 9223B		Analyzing Lab: 1015-GRANITE STATE ANALYTICAL SERVICES LLC							
ESCHERICHIA COLI	ABSENT	P-A/100ML			03/06/2024 13:10:00	03/07/2024 08:11:00	2525	10291	
TOTAL COLIFORMS	ABSENT	P-A/100ML			03/06/2024 13:10:00	03/07/2024 08:11:00	2500	10291	

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.