



ANALYTICAL RESULTS

Batch ID/Form: 2404-01728 - TOTAL COLIFORM RULE

Submitting Lab ID: 1015

PWS ID/Name: 0511030 - NORTH CONWAY WATER PCT - CONWAY

Report Date: 04/15/2024

Collector: MARK EWING

Phone: 603-356-5382

Collect Date: 04/10/2024 09:10:00

Lab Sample ID: 2404-01728-001

Matrix: WATER

Received: 04/10/2024 12:09:00

Sample Location ID: 001

Sample Type: ROUTINE-SAMPLE

Compliance Period: APR 2024

Description: CANNELLS COMPLEX

Receipt Temp.: 13 C

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
Analytical Method: 9223B		Analyzing Lab: 1015-GRANITE STATE ANALYTICAL SERVICES LLC							
ESCHERICHIA COLI	ABSENT	P-A/100ML			04/11/2024 12:52:00	04/12/2024 09:31:00	2525	10291	
TOTAL COLIFORMS	ABSENT	P-A/100ML			04/11/2024 12:52:00	04/12/2024 09:31:00	2500	10291	

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.