



ANALYTICAL RESULTS

Batch ID/Form: B400438 - TOTAL COLIFORM RULE

Submitting Lab ID: 3000

PWS ID/Name: 0761010 - EPPING WATER AND SEWER DEPT - EPPING

Report Date: 02/01/2024

Collector: NORMAN DIONNE

Phone: 603-679-5441

Collect Date: 01/30/2024 09:06:00

Lab Sample ID: B400438002

Matrix: WATER

Received: 01/30/2024 10:04:00

Sample Location ID: 006

Sample Type: ROUTINE-SAMPLE

Compliance Period: JAN 2024

Description: 157 MAIN ST

Receipt Temp.: 10 C

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
Analytical Method: 9223B		Analyzing Lab: 3000-NEW HAMPSHIRE DHHS PUBLIC HEALTH LABORATORIES							
ESCHERICHIA COLI	ABSENT	P-A/100ML			01/30/2024 11:07:00	01/31/2024 11:49:00	2525		
TOTAL COLIFORMS	ABSENT	P-A/100ML			01/30/2024 11:07:00	01/31/2024 11:49:00	2500		
Analytical Method: Field Result SM 9223B									
RESIDUAL FREE CHLORINE	0.79	MG/L							

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.