



ANALYTICAL RESULTS

Batch ID/Form: B400781 - TOTAL COLIFORM RULE

Submitting Lab ID: 3000

PWS ID/Name: 0761010 - EPPING WATER AND SEWER DEPT - EPPING

Report Date: 02/16/2024

Collector: ANTHONY SHEA

Phone: 603-679-5441

Collect Date: 02/14/2024 08:25:00

Lab Sample ID: B400781001

Matrix: WATER

Received: 02/14/2024 10:08:00

Sample Location ID: 001

Sample Type: ROUTINE-SAMPLE

Compliance Period: FEB 2024

Description: 213 MAIN ST

Receipt Temp.: 9 C

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
Analytical Method: 9223B		Analyzing Lab: 3000-NEW HAMPSHIRE DHHS PUBLIC HEALTH LABORATORIES							
ESCHERICHIA COLI	ABSENT	P-A/100ML			02/14/2024 10:33:00	02/15/2024 12:40:00	2525		
TOTAL COLIFORMS	ABSENT	P-A/100ML			02/14/2024 10:33:00	02/15/2024 12:40:00	2500		
Analytical Method: Field Result SM 9223B									
TOTAL RESIDUAL CHLORINE	0.87	MG/L							

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.