

29 HAZEN DR CONCORD NH 03302 Phone: (603) 271-2994 Fax:

## ANALYTICAL RESULTS

Batch ID/Form: B401293 - TOTAL COLIFORM RULE					Submitting Lab ID: 3000				
PWS ID/Name: 0761010 - EPPING WATER AND SEWER DEPT - EPPING						Report Date: 03/18/2024			
Collector: NORM DIONNE		<b>Phone:</b> 603-679-5171			Collect Date:	03/14/2024 09:05:00			
Lab Sample ID: B401293002		Matrix: WATER				Received:	: 03/14/2024 10:24:00		
Sample Location ID: 006		Sample Type: ROUTINE-SAMPLE				Compliance Period:	MAR 2024		
Description: 157 MAIN ST						Receipt Temp.:	10 C		
Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
Analytical Method:	223B	Analyzing Lab: 3000-NEW HAMPSHIRE DHHS PUBLIC HEALTH LABORATORIES							
ESCHERICHIA COLI	ABSENT	P-A/100ML			03/14/2024 11:04:00	03/15/2024 13:57:00	2525		
TOTAL COLIFORMS	ABSENT	P-A/100ML			03/14/2024 11:04:00	03/15/2024 13:57:00	2500		
Analytical Method: Field Result SM 9223B									
TOTAL RESIDUAL CHLORINE 1.25		MG/L							

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.