



**ANALYTICAL RESULTS**

**Batch ID/Form:** B402012 - TOTAL COLIFORM RULE

**Submitting Lab ID:** 3000

**PWS ID/Name:** 0761010 - EPPING WATER AND SEWER DEPT - EPPING

**Report Date:** 04/29/2024

**Collector:** NORM DIONNE

**Phone:** 603-679-5171

**Collect Date:** 04/25/2024 08:22:00

**Lab Sample ID:** B402012001

**Matrix:** WATER

**Received:** 04/25/2024 10:18:00

**Sample Location ID:** 001

**Sample Type:** ROUTINE-SAMPLE

**Compliance Period:** APR 2024

**Description:** 213 MAIN ST

**Receipt Temp.:** 9 C

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
<b>Analytical Method:</b> 9223B		<b>Analyzing Lab:</b> 3000-NEW HAMPSHIRE DHHS PUBLIC HEALTH LABORATORIES							
ESCHERICHIA COLI	ABSENT	P-A/100ML			04/25/2024 10:47:00	04/26/2024 13:18:00	2525		
TOTAL COLIFORMS	ABSENT	P-A/100ML			04/25/2024 10:47:00	04/26/2024 13:18:00	2500		
<b>Analytical Method:</b> Field Result									
TOTAL RESIDUAL CHLORINE	1.8	MG/L							

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.