



NELSON ANALYTICAL LAB
490 EAST INDUSTRIAL PARK DRIVE
MANCHESTER NH 03109
Phone: (603) 622-0200
Fax:

ANALYTICAL RESULTS

Batch ID/Form: 124030313.01 - TOTAL COLIFORM RULE Submitting Lab ID: 1005
PWS ID/Name: 1141020 - EMERALD LAKE - HILLSBOROUGH Report Date: 03/07/2024
Collector: D. MCGRAW Phone: 603-942-6138 Collect Date: 03/04/2024 11:45:00

Lab Sample ID: 124030313.01 Matrix: WATER Received: 03/05/2024 13:10:00
Sample Location ID: 019 Sample Type: ROUTINE-SAMPLE Compliance Period: MAR 2024
Description: 62 AUTUMN RD Receipt Temp.: 6.9 C
Batch Chlorine Residual: 0.20

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
Analytical Method: 20214204		Analyzing Lab: 1005-NELSON ANALYTICAL LLC							
ESCHERICHIA COLI	ABSENT	P-A/100ML			03/05/2024 14:48:00	03/06/2024 09:00:00	2525		
TOTAL COLIFORMS	ABSENT	P-A/100ML			03/05/2024 14:48:00	03/06/2024 09:00:00	2500		
Analytical Method: Field Result									
TOTAL RESIDUAL CHLORINE	0.20	MG/L							

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.