



ANALYTICAL RESULTS

Batch ID/Form: 276317 - TOTAL COLIFORM RULE

Submitting Lab ID: 1012

PWS ID/Name: 1521010 - MEREDITH WATER DEPT - MEREDITH

Report Date: 04/08/2024

Collector: MICHAEL THIBAUT

Phone: 603-279-3046

Collect Date: 04/05/2024 08:40:00

Lab Sample ID: 276317.02

Matrix: WATER

Received: 04/05/2024 10:32:00

Sample Location ID: O-01

Sample Type: REPEAT-SAMPLE

Compliance Period: APR 2024

Description: 63 MAIN ST

Receipt Temp.: 4.9 C

Batch Chlorine Residual: 0.62

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
---------	---------	-------	-----	----	---------------	---------------	--------------	---------	-------

Analytical Method: 20214204

Analyzing Lab: 1012-EASTERN ANALYTICAL INC

ESCHERICHIA COLI	ABSENT	P-A/100ML	1	1	04/05/2024 13:30:00	04/06/2024 09:40:00	3014		
TOTAL COLIFORMS	ABSENT	P-A/100ML	1	1	04/05/2024 13:30:00	04/06/2024 09:40:00	3100		

Analytical Method: Field Result

TOTAL RESIDUAL CHLORINE 0.62 MG/L