



ANALYTICAL RESULTS

Batch ID/Form: 278225 - TOTAL COLIFORM RULE

Submitting Lab ID: 1012

PWS ID/Name: 1521010 - MEREDITH WATER DEPT - MEREDITH

Report Date: 05/10/2024

Collector: MIKE THIBAUT

Phone: 603-279-3046

Collect Date: 05/09/2024 08:35:00

Lab Sample ID: 278225.01

Matrix: WATER

Received: 05/09/2024 14:00:00

Sample Location ID: 001

Sample Type: ROUTINE-SAMPLE

Compliance Period: MAY 2024

Description: WICKS LUMBER

Receipt Temp.: 3 C

Batch Chlorine Residual: 0.42

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
---------	---------	-------	-----	----	---------------	---------------	--------------	---------	-------

Analytical Method: 20214204

Analyzing Lab: 1012-EASTERN ANALYTICAL INC

ESCHERICHIA COLI	ABSENT	P-A/100ML	1	1	05/09/2024 14:15:00	05/10/2024 11:30:00	3014		
TOTAL COLIFORMS	ABSENT	P-A/100ML	1	1	05/09/2024 14:15:00	05/10/2024 11:30:00	3100		

Analytical Method: Field Result

TOTAL RESIDUAL CHLORINE 0.42 MG/L