



**ANALYTICAL RESULTS**

**Batch ID/Form:** 278225 - TOTAL COLIFORM RULE

**Submitting Lab ID:** 1012

**PWS ID/Name:** 1521010 - MEREDITH WATER DEPT - MEREDITH

**Report Date:** 05/10/2024

**Collector:** MIKE THIBAUT

**Phone:** 603-279-3046

**Collect Date:** 05/09/2024 08:50:00

**Lab Sample ID:** 278225.02

**Matrix:** WATER

**Received:** 05/09/2024 14:00:00

**Sample Location ID:** 003

**Sample Type:** ROUTINE-SAMPLE

**Compliance Period:** MAY 2024

**Description:** MEREDITH TOWN OFFICE

**Receipt Temp.:** 3 C

**Batch Chlorine Residual:** 0.48

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
---------	---------	-------	-----	----	---------------	---------------	--------------	---------	-------

**Analytical Method:** 20214204

**Analyzing Lab:** 1012-EASTERN ANALYTICAL INC

ESCHERICHIA COLI	ABSENT	P-A/100ML	1	1	05/09/2024 14:15:00	05/10/2024 11:30:00	3014		
TOTAL COLIFORMS	ABSENT	P-A/100ML	1	1	05/09/2024 14:15:00	05/10/2024 11:30:00	3100		

**Analytical Method:** Field Result

TOTAL RESIDUAL CHLORINE	0.48	MG/L							
-------------------------	------	------	--	--	--	--	--	--	--

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.