NH DPHS PHL WATER ANALYSIS LAB
29 HAZEN DR
CONCORD NH 03302
Phone: (603) 271-2994
Fax:

ANALYTICAL RESULTS

Batch ID/Form: B300200 - TOTAL COLIFORM RULE
Submitting Lab ID: 3000
PWS ID/Name: 2041010 - RYE WATER DIST - RYE
Report Date: 01/13/2023
Collector: ARIK JONES
Phone: 603-817-1344
Collect Date: 01/11/2023 13:06:00

Lab Sample ID: B300200005
Matrix: WATER
Received: 01/11/2023 14:48:00
Sample Location ID: 015
Sample Type: ROUTINE-SAMPLE
Compliance Period: JAN 2023
Description: 271 LAFAYETTE RD
Receipt Temp.: 9 C

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
Analytical Method: 9223B					**Analyzing Lab: 3000-NEW HAMPSHIRE DHHS PUBLIC HEALTH LABORATORIES**				
ESCHERICHIA COLI	ABSENT	P-A/100ML			01/11/2023 15:32:00	01/12/2023 11:35:00	2525		
TOTAL COLIFORMS	ABSENT	P-A/100ML			01/11/2023 15:32:00	01/12/2023 11:35:00	2500		
Analytical Method: Field Result SM 9223B									
TOTAL RESIDUAL CHLORINE	1.2	MG/L							

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.