



ANALYTICAL RESULTS

Batch ID/Form: B401247 - TOTAL COLIFORM RULE

Submitting Lab ID: 3000

PWS ID/Name: 2041010 - RYE WATER DIST - RYE

Report Date: 03/14/2024

Collector: ARIK JONES

Phone: 603-814-1344

Collect Date: 03/12/2024 09:00:00

Lab Sample ID: B401247003

Matrix: WATER

Received: 03/12/2024 11:57:00

Sample Location ID: 12

Sample Type: ROUTINE-SAMPLE

Compliance Period: MAR 2024

Description: PARSONS ROAD SAMPLING STATION

Receipt Temp.: 10 C

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
---------	---------	-------	-----	----	---------------	---------------	--------------	---------	-------

Analytical Method: 9223B

Analyzing Lab: 3000-NEW HAMPSHIRE DHHS PUBLIC HEALTH LABORATORIES

ESCHERICHIA COLI	ABSENT	P-A/100ML			03/12/2024 14:11:00	03/13/2024 10:15:00	2525		
TOTAL COLIFORMS	ABSENT	P-A/100ML			03/12/2024 14:11:00	03/13/2024 10:15:00	2500		

Analytical Method: Field Result SM 9223B

RESIDUAL FREE CHLORINE	0.4	MG/L							
------------------------	-----	------	--	--	--	--	--	--	--

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.