NELSON ANALYTICAL LAB
150 KAYE ST.
MANCHESTER NH 03109
Phone: (603) 622-0200
Fax:

# ANALYTICAL RESULTS

**Batch ID/Form:** 117110832 - TOTAL COLIFORM RULE **Submitting Lab ID:** 1005

**PWS ID/Name:** 2542160 - HADLEIGH WOODS - WINDHAM **Report Date:** 11/14/2017

**Collector:** STEPHEN FOURNIER **Phone:** 603-362-5333 **Collect Date:** 11/09/2017 12:35

---

**Lab Sample ID:** 117110832.02 **Matrix:** DRINKING WATER **Received:** 11/09/2017 13:40

**Sample Location ID:** O-1 **Sample Type:** REPEAT-SAMPLE **Compliance Period:** NOV 2017

**Description:** 15 FLATROCK RIDGE **Receipt Temp.:** 15 C

| Analyte | Results | Units | RDL | DF | Prepared Date | Analysis Date | Analyte Code | Analyst | Qual. |
|---|---|---|---|---|---|---|---|---|---|
| **Analytical Method: 20214204** | | | | | **Analyzing Lab: 1005-NELSON ANALYTICAL LLC** | | | | |
| ESCHERICHIA COLI | ABSENT | P-A/100ML | | | 11/09/2017 14:30 | 11/10/2017 09:15 | 2525 | | |
| TOTAL COLIFORMS | ABSENT | P-A/100ML | | | 11/09/2017 14:30 | 11/10/2017 09:15 | 2500 | | |
| **Analytical Method: Field Result** | | | | | | | | | |
| FREE CHLORINE RESIDUAL | 0.04 | MG/L | | | | | | | |

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.