NELSON ANALYTICAL LAB
150 KAYE ST.
MANCHESTER NH 03109
Phone: (603) 622-0200
Fax:

ANALYTICAL RESULTS

Batch ID/Form: 117120898.01 - TOTAL COLIFORM RULE
Submitting Lab ID: 1005
PWS ID/Name: 2542160 - HADLEIGH WOODS - WINDHAM
Report Date: 12/13/2017
Collector: STEPHEN FOURNIER
Phone: 603-362-1916
Collect Date: 12/11/2017 14:15

Lab Sample ID: 17120898.01
Matrix: DRINKING WATER
Received: 12/11/2017 15:40
Sample Location ID: 001
Sample Type: ROUTINE-SAMPLE
Compliance Period: DEC 2017
Description: 17 FLAT ROCK RD OUTSIDE TAP
Receipt Temp.: 10 C

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
Analytical Method: 20214204			**Analyzing Lab: 1005-NELSON ANALYTICAL LLC**						
ESCHERICHIA COLI	ABSENT	P-A/100ML			12/11/2017 16:45	12/12/2017 13:40	2525		
TOTAL COLIFORMS	ABSENT	P-A/100ML			12/11/2017 16:45	12/12/2017 13:40	2500		
Analytical Method: Field Result									
FREE CHLORINE RESIDUAL	0.47	MG/L							

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.