



ANALYTICAL RESULTS

Batch ID/Form: 292238 - TOTAL COLIFORM RULE

Submitting Lab ID: 1012

PWS ID/Name: 1721010 - NEW LONDON SPRINGFIELD WATER - NEW LONDON

Report Date: 01/09/2025

Collector: JON DAME

Phone: 603-526-4441

Collect Date: 01/08/2025 09:05:00

Lab Sample ID: 292238.01

Matrix: WATER

Received: 01/08/2025 10:25:00

Sample Location ID: 003

Sample Type: ROUTINE-SAMPLE

Compliance Period: JAN 2025

Description: 40 S PLEASANT ST NL HWY DEPT

Receipt Temp.: 4 C

Batch Chlorine Residual: 0.48

| Analyte | Results | Units | RDL | DF | Prepared Date | Analysis Date | Analyte Code | Analyst | Qual. |
|---------|---------|-------|-----|----|---------------|---------------|--------------|---------|-------|
|---------|---------|-------|-----|----|---------------|---------------|--------------|---------|-------|

Analytical Method: 20214204

Analyzing Lab: 1012-EUROFINS ENVIRONMENT TESTING EASTERN ANALYTICAL #1012

| | | | | | | | | | |
|------------------|--------|-----------|---|---|------------------------|------------------------|------|--|--|
| ESCHERICHIA COLI | ABSENT | P-A/100ML | 1 | 1 | 01/08/2025 13:45:00 | 01/09/2025 11:15:00 | 3014 | | |
| TOTAL COLIFORMS | ABSENT | P-A/100ML | 1 | 1 | 01/08/2025 13:45:00 | 01/09/2025 11:15:00 | 3100 | | |

Analytical Method: Field Result

| | | | | | | | | | |
|-------------------------|------|------|--|--|--|--|--|--|--|
| TOTAL RESIDUAL CHLORINE | 0.48 | MG/L | | | | | | | |
|-------------------------|------|------|--|--|--|--|--|--|--|

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.