



**ANALYTICAL RESULTS**

**Batch ID/Form:** 283601 - TOTAL COLIFORM RULE

**Submitting Lab ID:** 1012

**PWS ID/Name:** 1721010 - NEW LONDON SPRINGFIELD WATER - NEW LONDON

**Report Date:** 08/12/2024

**Collector:** ROB THORP

**Phone:** 603-526-4441

**Collect Date:** 08/09/2024 10:30:00

**Lab Sample ID:** 283601.01

**Matrix:** WATER

**Received:** 08/09/2024 15:00:00

**Sample Location ID:** 018

**Sample Type:** REPEAT-SAMPLE

**Compliance Period:** AUG 2024

**Description:** 237 MAIN ST FIRE DEPT

**Receipt Temp.:** 3 C

**Batch Chlorine Residual:** 0.11

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
---------	---------	-------	-----	----	---------------	---------------	--------------	---------	-------

**Analytical Method:** 20214204

**Analyzing Lab:** 1012-EUROFINS ENVIRONMENT TESTING EASTERN ANALYTICAL #1012

ESCHERICHIA COLI	ABSENT	P-A/100ML	1	1	08/09/2024 15:10:00	08/10/2024 10:10:00	3014		
TOTAL COLIFORMS	PRESENT	P-A/100ML	1	1	08/09/2024 15:10:00	08/10/2024 10:10:00	3100		

**Analytical Method:** Field Result

TOTAL RESIDUAL CHLORINE 0.11 MG/L

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.