



ANALYTICAL RESULTS

Batch ID/Form: 284873 - TOTAL COLIFORM RULE

Submitting Lab ID: 1012

PWS ID/Name: 1721010 - NEW LONDON SPRINGFIELD WATER - NEW LONDON

Report Date: 09/05/2024

Collector: JON DAME

Phone: 603-526-4441

Collect Date: 09/04/2024 09:40:00

Lab Sample ID: 284873.01

Matrix: WATER

Received: 09/04/2024 11:05:00

Sample Location ID: 003

Sample Type: ROUTINE-SAMPLE

Compliance Period: SEP 2024

Description: 40 S PLEASANT ST NL HWY DEPT

Receipt Temp.: 5.4 C

Batch Chlorine Residual: 0.02

| Analyte | Results | Units | RDL | DF | Prepared Date | Analysis Date | Analyte Code | Analyst | Qual. |
|--|---------|--|-----|----|------------------------|------------------------|--------------|---------|-------|
| Analytical Method: 20214204 | | Analyzing Lab: 1012-EUROFINS ENVIRONMENT TESTING EASTERN ANALYTICAL #1012 | | | | | | | |
| ESCHERICHIA COLI | ABSENT | P-A/100ML | 1 | 1 | 09/04/2024 13:15:00 | 09/05/2024 11:00:00 | 3014 | | |
| TOTAL COLIFORMS | ABSENT | P-A/100ML | 1 | 1 | 09/04/2024 13:15:00 | 09/05/2024 11:00:00 | 3100 | | |
| Analytical Method: Field Result | | | | | | | | | |
| TOTAL RESIDUAL CHLORINE | 0.02 | MG/L | | | | | | | |

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.