



**ANALYTICAL RESULTS**

**Batch ID/Form:** 290548 - TOTAL COLIFORM RULE

**Submitting Lab ID:** 1012

**PWS ID/Name:** 1721010 - NEW LONDON SPRINGFIELD WATER - NEW LONDON

**Report Date:** 12/05/2024

**Collector:** JON DAME

**Phone:** 603-526-4441

**Collect Date:** 12/04/2024 08:49:00

**Lab Sample ID:** 290548.02

**Matrix:** WATER

**Received:** 12/04/2024 10:31:00

**Sample Location ID:** 018

**Sample Type:** ROUTINE-SAMPLE

**Compliance Period:** DEC 2024

**Description:** 237 MAIN ST FIRE DEPT

**Receipt Temp.:** 5.2 C

**Batch Chlorine Residual:** 0.60

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
<b>Analytical Method:</b> 20214204		<b>Analyzing Lab: 1012-EUROFINS ENVIRONMENT TESTING EASTERN ANALYTICAL #1012</b>							
ESCHERICHIA COLI	ABSENT	P-A/100ML	1	1	12/04/2024 13:40:00	12/05/2024 11:20:00	3014		
TOTAL COLIFORMS	ABSENT	P-A/100ML	1	1	12/04/2024 13:40:00	12/05/2024 11:20:00	3100		
<b>Analytical Method:</b> Field Result									
TOTAL RESIDUAL CHLORINE	0.60	MG/L							

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.