



ANALYTICAL RESULTS

Batch ID/Form: 2006-00465 - TOTAL COLIFORM RULE

Submitting Lab ID: 1015

PWS ID/Name: 2089010 - SANDOWN TOWN HALL FIRE STATION - SANDOWN

Report Date: 06/05/2020

Collector: MARK TOLMAN

Phone: 603-994-1938

Collect Date: 06/02/2020 16:35:00

Lab Sample ID: 2006-00465-001

Matrix: WATER

Received: 06/03/2020 07:14:00

Sample Location ID: 001

Sample Type: ROUTINE-SAMPLE

Compliance Period: JUN 2020

Description: MENS ROOM SINK TOWN HALL

Receipt Temp.: 5.6 C

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
Analytical Method: 9223B		Analyzing Lab: 1015-GRANITE STATE ANALYTICAL SERVICES LLC							
ESCHERICHIA COLI	ABSENT	P-A/100ML			06/03/2020 12:53:00	06/04/2020 09:40:00	2525	5502	
TOTAL COLIFORMS	ABSENT	P-A/100ML			06/03/2020 12:53:00	06/04/2020 09:40:00	2500	5502	