



ANALYTICAL RESULTS

Batch ID/Form: 2009-02505 - TOTAL COLIFORM RULE

Submitting Lab ID: 1015

PWS ID/Name: 2089010 - SANDOWN TOWN HALL FIRE STATION - SANDOWN

Report Date: 09/21/2020

Collector: MARK TOLMAN

Phone: 603-994-1938

Collect Date: 09/16/2020 16:30:00

Lab Sample ID: 2009-02505-001

Matrix: WATER

Received: 09/17/2020 10:31:00

Sample Location ID: 001

Sample Type: ROUTINE-SAMPLE

Compliance Period: SEP 2020

Description: MENS ROOM SINK TOWN HALL

Receipt Temp.: 6 C

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
Analytical Method: 9223B		Analyzing Lab: 1015-GRANITE STATE ANALYTICAL SERVICES LLC							
ESCHERICHIA COLI	ABSENT	P-A/100ML			09/17/2020 12:06:00	09/18/2020 09:05:00	2525	5502	
TOTAL COLIFORMS	ABSENT	P-A/100ML			09/17/2020 12:06:00	09/18/2020 09:05:00	2500	5502	